



LUMINAIRE TESTING LABORATORY, INC.

SUSTAINING MEMBER of the IESNA

905 Harrison Street · Allentown, PA 18103 · 610-770-1044 · Fax 610-770-8912 · www.LuminaireTesting.com

LTL NUMBER: 09225
PREPARED FOR: EGRESSLITE
CATALOG NUMBER: RM36

DATE: 09-07-2005

LUMINAIRE: FORMED STEEL HOUSING, FORMED STEEL REFLECTORS WITHIN CLEAR POLYCARBONATE ENCLOSURE. SPECULAR POLYCARBONATE REFLECTOR ABOVE LAMP ENCLOSURE.

LAMPS: TWO 18 WATT T5 WEDGE XENON LAMPS RATED AT 250 LUMENS EACH.


LAMP CATALOG NUMBER: THHC LIGHTING XELOGEN 18W

MOUNTING: WALL

Table with columns: CANDELA DISTRIBUTION (0.0 to 180.0) and FLUX (5 to 36). Rows represent candela values from 0 to 180.

ZONAL LUMEN SUMMARY table with columns: ZONE, LUMENS, % LAMP, % FIXT. Rows show lumen distribution across zones from 0-30 to 0-180.

TOTAL LUMINAIRE EFFICIENCY: 57.1%
CIE TYPE: SEMI-DIRECT
PLANE: 0-DEG 90-DEG 180-DEG
SPACING CRITERIA: 1.6 1.5 0.6



TESTED BY HERSCHEL SCHRECK
CHECKED BY MIKE GRATHER

THIS REPORT BASED ON LM-46 AND OTHER PERTINENT IESNA PROCEDURES.



LTL NUMBER: 09225
PREPARED FOR: EGRESSLITE


DATE: 09-07-2005

ZONAL LUMEN SUMMARY

0- 5	1.
5- 10	4.
10- 15	6.
15- 20	7.
20- 25	7.
25- 30	9.
30- 35	10.
35- 40	11.
40- 45	12.
45- 50	13.
50- 55	15.
55- 60	16.
60- 65	17.
65- 70	17.
70- 75	17.
75- 80	17.
80- 85	18.
85- 90	17.
90- 95	18.
95-100	14.
100-105	11.
105-110	9.
110-115	6.
115-120	4.
120-125	2.
125-130	2.
130-135	1.
135-140	1.
140-145	1.
145-150	0.
150-155	0.
155-160	0.
160-165	0.
165-170	0.
170-175	0.
175-180	0.

PLANE :	0-DEG	90-DEG
LUMINOUS LENGTH:	1.500	2.375
HEIGHT OF SIDE:	2.375	2.375

LUMINANCE IN CANDELA PER SQUARE METER			
ANGLE	AVERAGE	AVERAGE	AVERAGE
IN DEG	0-DEG	45-DEG	90-DEG
0	23058.	23058.	23058.
45	16820.	19136.	22130.
55	23481.	18047.	22400.
65	23642.	18223.	22167.
75	24639.	18313.	18655.
85	25824.	19987.	17987.





LTL NUMBER: 09225

DATE: 09-07-2005

PREPARED FOR: EGRESSLITE

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

EFFECTIVE FLOOR CAVITY REFLECTANCE 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	65	65	65	65	62	62	62	62	56	56	56	50	50	50	45	45	45	43
1	56	52	49	46	53	50	46	44	44	42	40	40	38	36	35	34	32	30
2	50	44	39	35	47	42	37	34	37	34	31	33	30	28	29	27	25	23
3	45	38	32	28	42	36	31	27	32	28	25	29	25	22	25	23	20	18
4	41	33	28	23	39	32	26	22	28	24	21	25	22	19	22	19	17	15
5	37	29	24	20	35	28	23	19	25	21	17	22	19	16	20	17	14	13
6	34	26	21	17	32	25	20	16	22	18	15	20	16	13	18	15	12	11
7	31	23	18	14	30	22	17	14	20	16	13	18	14	11	16	13	10	9
8	29	21	16	12	27	20	15	12	18	14	11	16	13	10	15	11	9	8
9	27	19	14	11	26	18	14	10	16	12	10	15	11	9	13	10	8	7
10	25	17	13	10	24	17	12	9	15	11	9	14	10	8	12	9	7	6

NOTE: THE ZONAL CAVITY CALCULATION TECHNIQUE IS ACCURATE WHEN LUMINAIRES WITH SYMMETRIC CANDELA DISTRIBUTIONS ARE EMPLOYED AND WHEN THE LUMINAIRES ARE LOCATED SYMMETRICALLY THROUGHOUT THE ROOM. THIS UNIT HAS SPECIAL CHARACTERISTICS AND THEREFORE THESE COEFFICIENTS SHOULD BE USED WITH CAUTION.

THIS TEST WAS CONDUCTED USING RELATIVE PHOTOMETRY TECHNIQUES ACCORDING TO STANDARD IESNA PROCEDURES. THE USER MUST THEREFORE USE CAUTION IN THE FOLLOWING SITUATIONS: 1) ACCORDING TO IESNA PROCEDURES, THE BALLAST(S) AND LAMP(S) ARE PRESUMED TO PRODUCE 100% OF RATED OUTPUT. AN APPROPRIATE BALLAST FACTOR MUST BE APPLIED TO THE LUMEN OUTPUT RATINGS AND LUMINOUS INTENSITY VALUES GIVEN. 2) THIS TEST WAS CONDUCTED IN A CONTROLLED LABORATORY ENVIRONMENT, FIELD PERFORMANCE MAY DIFFER.